



City of  
LEMON GROVE FIRE DEPARTMENT  
*Fire Prevention Bureau*

7853 Central Avenue  
Lemon Grove, CA 91945  
619-825-3835

***Tim Smith Deputy Chief/Fire Marshal***

## **Christmas Tree Lot Information Sheet**

1. Provide a minimum of one 2A:10B:C fire extinguisher for every 50 feet of travel within the tree lot.
2. Maintain a minimum clearance of 10 feet between trees and any buildings or structures. Trees may not be stored or displayed beneath any overhanging portion of a building.
3. Maintain a minimum aisle clearance of 44 inches between rows of trees (36 inches between rows of trees and fences).
4. Provide fire department access to all portions of the lot or buildings on the lot that are greater than 150 feet from access roads. Required fire lanes must be a minimum of 20 feet wide.
5. Access gates to tree lots must remain open at all times during business hours.
6. All electrical installations (lighting, etc.) must meet applicable codes.

Note: These include most of the requirements for Christmas Tree Lots. Some situations may involve requirements not on this list. These situations can be addressed during on-site inspections or by calling us if you have a situation that is not addressed here. If you have any questions regarding these requirements or questions specific to your situation, please call (619) 825-3835.